

SPECIFICATION DATA

TRAMCO Series 2500 Industrial Sump Pump

TRAMCO's Series 2500 Vertical Sump Pumps are engineered and precision built for years of dependable service. Quality materials and construction, together with a mechanical shaft seal design, allow continuous operation in temperatures up to 200° F.

Applications

Sump Drainage
Liquid Transfer
Dewatering
Industrial Process

Pump

The Series 2500 is a centrifugal type pump fitted with a semi-open impeller accurately machined and balanced for smooth, quiet operation.

Mechanical Shaft Seal

Series 2500 pumps are fitted with a mechanical shaft seal which prevents the liquid being pumped from entering the lower sleeve bearing while retaining the lubrication in the pump. Several seals are available to meet your application.

Pump Lubrication

Tramco's lubrication system provides continuous lubrication to shaft, self lubricated intermediate and lower sleeve bearings. It eliminates the need for external grease lines or product lubricated sleeve bearings.

Shaft Column Pipe

The pump is manufactured with schedule 80 hot dipped galvanized steel as standard.

Shaft

Size 1" high accuracy, grade 1215 that is turned, ground and polished. Shafts are also available in stainless steel. External adjustment nut.

Discharge Pipe

The pump is manufactured with schedule 40 hot dipped galvanized steel as standard.

Motor Support Bracket

The heavy cast pedestal is accurately machined to house the thrust bearing and align the motor.

Thrust Bearing

The thrust ball bearing is grease lubricated and elevated above the cover plate for protection from dirt and moisture.

Floor Plate Suspension Cover

Heavy duty steel. Tramco will fabricate covers to duplicate existing pumps and piping.

Motors

The motor and pump shafts are connected by a flexible coupling that allows the motor to be easily removed without distributing the pump and piping.

Strainer

Made of heavy cast iron construction.


Float Control (Optional)

Heavy duty pedestal mounted float switch is available. Float ball is stainless steel. Refer to page 95 for details.

Basin Cover (Optional)

Heavy duty basin cover capable of supporting vertical suspended pumps and motors. Covers are available for simplex, duplex or other configurations. Refer to page 97 for details.

TRAMCO
PUMP COMPANY



QUALITY YOU CAN COUNT ON,
A NAME YOU CAN TRUST

Since 1924

TRAMCO PUMP COMPANY


1500 West Adams Street Chicago, Illinois 60607

Phone 312-243-5800 Fax 312-243-0702 Visit our Web Site at TRAMCOPUMP.COM

TRAMCO Series 2500 Sump Pumps



2500 Series Composite Curves 1750 RPM



Typical Specifications for a Duplex Vertical Sump Pump System

Contractor shall furnish and install as shown on the plans a duplex Vertical sump pump system as designed and manufactured by Tramco Pump Company of Chicago, Illinois. The sump pump system shall consist of Two Tramco Vertical sump pumps and motors, a mechanical alternator assembly, emergency float switch and HWA assembly, duplex control panel, basin and basin cover.

Pumps: Furnish a duplex set of Tramco 2500 series vertical pumps each rated to deliver ____ GPM at ____ TDH. The pumps shall have heavy duty cast iron casings, semi-open type balanced cast iron impellers, grade 1215 turned, ground and polished shafting, raised upper grease lubricated ball thrust bearings. The pump shall be furnished with a 1-1/2 to 3" NPT schedule 40 galvanized discharge pipe and steel pump plate. The pump shall be fabricated with Schedule 80 galvanized shaft column constructed with an oil lubricated design having self lubricated intermediate and lower sleeve bearing(s), type 21 buna-N, Carbon vs. Ceramic mechanical shaft seal to prevent contamination of the lower sleeve bearing while providing continuous lubrication for the shaft. Pumps using product lubrication or grease lubricated bearings shall not be considered equal. Pumps using lip seals in lieu of a mechanical seal shall not be approved. Pumps using material other than galvanized steel of the above mentioned schedules, shall not be approved.

Motors: The motors shall be ____ HP, ____ RPM, ____ VOLT, ____ PHASE, ____ HZ, Totally enclosed fan cooled enclosure connected to the pump by use of a Woods style coupling assembly.

Control panel: Furnish for wall mounting a U.L. labeled Nema-____ Duplex control panel with through the door main disconnect switch. Furnish for each pump a full voltage magnetic starter with properly size 3 leg overload protection, fuse block with fuses, Hand-Off-Auto selector switch, pump running light, a high water alarm horn, light and silence button and a control transformer for 115 volt control circuit. The control panel shall be factory internally prewired and tested in accordance with the provisions of the national electric code. All control wires shall be individually numbered and each component shall be labeled accordingly. All internal wiring shall be copper stranded, A.W.G., with a minimum insulation of 90° C. The complete assembly shall have a U.L. listing mark for industrial control panel and the enclosure. The enclosure shall be finished inside and out with a machinery grade enamel. The control panel shall include a terminal strip for connection of float control wiring as required for proper installation. All control wiring shall be neatly tucked inside wire raceways.

Float Controls: Furnish a Nema-____ combination mechanical alternating float switch assembly with stainless steel float ball, solid brass float rod and float stops. The assembly shall consist of a pedestal base for basin cover mounting. Furnish a Nema-emergency float switch assembly with stainless steel float ball, solid brass float rod and float stops for activation of the pump and high water alarm if the alternator or first pump fails. The assembly shall consist of a pedestal base for basin cover mounting.

Basin Cover: Furnish a duplex steel basin cover ____ Dia. including all necessary openings for pumps, vent, inspection cover and float assemblies. The basin cover shall be ____" thick steel plate and shall be painted with a corrosion resistant paint.

TRAMCO PUMP COMPANY

1500 West Adams Street Chicago, Illinois 60607

Phone 312-243-5800 Fax 312-243-0702 Visit our Web Site at TRAMCOPUMP.COM